

Radon test result report for:

**CENTRAL LINN SCHOOLS  
ELEMENTRY**

| Kit #   | Room Id   | Started               | Ended                 | pCi/L     | Analyzed   |
|---------|-----------|-----------------------|-----------------------|-----------|------------|
| 7864501 | 1         | 2017-06-28 @ 10:00 am | 2017-06-30 @ 1:00 pm  | < 0.3     | 2017-07-03 |
| 7864516 | 10        | 2017-06-28 @ 1:00 pm  | 2017-06-30 @ 1:00 pm  | < 0.3     | 2017-07-03 |
| 7864517 | 11        | 2017-06-28 @ 1:00 pm  | 2017-06-30 @ 1:00 pm  | < 0.3     | 2017-07-03 |
| 7864518 | 12        | 2017-06-28 @ 1:00 pm  | 2017-06-30 @ 1:00 pm  | < 0.3     | 2017-07-03 |
| 7864542 | 13        | 2017-06-28 @ 2:00 pm  | 2017-06-30 @ 2:00 pm  | 0.7 ± 0.3 | 2017-07-03 |
| 7864520 | 14        | 2017-06-28 @ 2:00 pm  | 2017-06-30 @ 2:00 pm  | 0.6 ± 0.3 | 2017-07-03 |
| 7864519 | 15        | 2017-06-28 @ 2:00 pm  | 2017-06-30 @ 2:00 pm  | < 0.3     | 2017-07-03 |
| 7864409 | 16        | 2017-06-28 @ 2:00 pm  | 2017-06-30 @ 2:00 pm  | < 0.3     | 2017-07-03 |
| 7864526 | 17        | 2017-06-28 @ 2:00 pm  | 2017-06-30 @ 2:00 pm  | 0.5 ± 0.3 | 2017-07-03 |
| 7864521 | 18        | 2017-06-28 @ 2:00 pm  | 2017-06-30 @ 2:00 pm  | < 0.3     | 2017-07-03 |
| 7864522 | 19        | 2017-06-28 @ 2:00 pm  | 2017-06-30 @ 2:00 pm  | 0.6 ± 0.3 | 2017-07-03 |
| 7856804 | 2         | 2017-06-28 @ 11:00 am | 2017-06-30 @ 1:00 pm  | 0.8 ± 0.3 | 2017-07-03 |
| 7864523 | 20        | 2017-06-28 @ 2:00 pm  | 2017-06-30 @ 2:00 pm  | < 0.3     | 2017-07-03 |
| 7864524 | 21        | 2017-06-28 @ 2:00 pm  | 2017-06-30 @ 2:00 pm  | < 0.3     | 2017-07-03 |
| 7864525 | 22        | 2017-06-28 @ 2:00 pm  | 2017-06-30 @ 2:00 pm  | 0.6 ± 0.3 | 2017-07-03 |
| 7864532 | 23        | 2017-06-28 @ 3:00 pm  | 2017-06-30 @ 3:00 pm  | 0.6 ± 0.3 | 2017-07-03 |
| 7864531 | 24        | 2017-06-28 @ 3:00 pm  | 2017-06-30 @ 3:00 pm  | 1.0 ± 0.3 | 2017-07-03 |
| 7864528 | 25        | 2017-06-28 @ 3:00 pm  | 2017-06-30 @ 3:00 pm  | 0.6 ± 0.3 | 2017-07-03 |
| 7864529 | 26        | 2017-06-28 @ 3:00 pm  | 2017-06-30 @ 3:00 pm  | 0.6 ± 0.3 | 2017-07-03 |
| 7864403 | 28        | 2017-06-28 @ 9:00 am  | 2017-06-30 @ 12:00 pm | 2.4 ± 0.4 | 2017-07-03 |
| 7856801 | 29        | 2017-06-28 @ 9:00 am  | 2017-06-30 @ 12:00 pm | 1.3 ± 0.3 | 2017-07-03 |
| 7864508 | 3         | 2017-06-28 @ 11:00 am | 2017-06-30 @ 1:00 pm  | 0.7 ± 0.3 | 2017-07-03 |
| 7864407 | 30        | 2017-06-28 @ 9:00 am  | 2017-06-30 @ 12:00 pm | 1.0 ± 0.3 | 2017-07-03 |
| 7864509 | 4         | 2017-06-28 @ 11:00 am | 2017-06-30 @ 1:00 pm  | 0.7 ± 0.3 | 2017-07-03 |
| 7864510 | 5         | 2017-06-28 @ 11:00 am | 2017-06-30 @ 1:00 pm  | 0.8 ± 0.3 | 2017-07-03 |
| 7864511 | 6         | 2017-06-28 @ 11:00 am | 2017-06-30 @ 1:00 pm  | 0.9 ± 0.3 | 2017-07-03 |
| 7864512 | 7         | 2017-06-28 @ 11:00 am | 2017-06-30 @ 1:00 pm  | 0.7 ± 0.3 | 2017-07-03 |
| 7864513 | 8         | 2017-06-28 @ 11:00 am | 2017-06-30 @ 1:00 pm  | 0.6 ± 0.3 | 2017-07-03 |
| 7864515 | 9         | 2017-06-28 @ 12:00 pm | 2017-06-30 @ 1:00 pm  | 0.9 ± 0.3 | 2017-07-03 |
| 7864505 | AUX GYM   | 2017-06-28 @ 9:00 am  | 2017-06-30 @ 12:00 pm | 0.8 ± 0.3 | 2017-07-03 |
| 7864410 | BIG GYM   | 2017-06-28 @ 9:00 am  | 2017-06-30 @ 12:00 pm | 0.6 ± 0.3 | 2017-07-03 |
| 7864405 | BIG GYM   | 2017-06-28 @ 9:00 am  | 2017-06-30 @ 12:00 pm | 0.7 ± 0.3 | 2017-07-03 |
| 7856807 | BIG GYM   | 2017-06-28 @ 9:00 am  | 2017-06-30 @ 12:00 pm | 0.7 ± 0.3 | 2017-07-03 |
| 7864406 | BIG GYM   | 2017-06-28 @ 9:00 am  | 2017-06-30 @ 12:00 pm | 0.9 ± 0.3 | 2017-07-03 |
| 7864404 | CAFATERIA | 2017-06-28 @ 9:00 am  | 2017-06-30 @ 12:00 pm | 0.9 ± 0.3 | 2017-07-03 |
| 7864408 | CAFATERIA | 2017-06-28 @ 9:00 am  | 2017-06-30 @ 12:00 pm | 0.7 ± 0.3 | 2017-07-03 |
| 7864536 | LIBRARY   | 2017-06-28 @ 2:00 pm  | 2017-06-30 @ 2:00 pm  | 0.8 ± 0.3 | 2017-07-03 |

Radon test result report for:

**CENTRAL LINN SCHOOLS  
ELEMENTARY**

| <b>Kit #</b> | <b>Room Id</b> | <b>Started</b>        | <b>Ended</b>          | <b>pCi/L</b> | <b>Analyzed</b> |
|--------------|----------------|-----------------------|-----------------------|--------------|-----------------|
| 7864530      | LIBRARY        | 2017-06-28 @ 2:00 pm  | 2017-06-30 @ 2:00 pm  | 0.8 ± 0.3    | 2017-07-03      |
| 7864401      | LOBBY          | 2017-06-28 @ 9:00 am  | 2017-06-30 @ 12:00 pm | < 0.3        | 2017-07-03      |
| 7864402      | LOBBY          | 2017-06-28 @ 9:00 am  | 2017-06-30 @ 12:00 pm | 0.7 ± 0.3    | 2017-07-03      |
| 7864503      | LOUNGE         | 2017-06-28 @ 10:00 am | 2017-06-30 @ 1:00 pm  | 0.6 ± 0.3    | 2017-07-03      |
| 7864507      | MAIN OFFICE    | 2017-06-28 @ 10:00 am | 2017-06-30 @ 12:00 pm | 0.8 ± 0.3    | 2017-07-03      |
| 7864504      | N. HALL        | 2017-06-28 @ 11:00 am | 2017-06-30 @ 1:00 pm  | < 0.3        | 2017-07-03      |
| 7856802      | NURSE OFFICE   | 2017-06-28 @ 10:00 am | 2017-06-30 @ 12:00 pm | 1.0 ± 0.3    | 2017-07-03      |
| 7856803      | PE OFFICE      | 2017-06-28 @ 11:00 am | 2017-06-30 @ 1:00 pm  | 0.5 ± 0.3    | 2017-07-03      |
| 7864506      | PRIN. OFFICE   | 2017-06-28 @ 9:00 am  | 2017-06-30 @ 12:00 pm | 0.7 ± 0.3    | 2017-07-03      |
| 7864533      | QUITE ROOM     | 2017-06-28 @ 3:00 pm  | 2017-06-30 @ 2:00 pm  | < 0.3        | 2017-07-03      |
| 7864514      | S. HALL        | 2017-06-28 @ 11:00 am | 2017-06-30 @ 1:00 pm  | 0.6 ± 0.3    | 2017-07-03      |
| 7864527      | SM LIB. OFFICE | 2017-06-28 @ 2:00 pm  | 2017-06-30 @ 2:00 pm  | < 0.3        | 2017-07-03      |
| 7864502      | VP OFFICE      | 2017-06-28 @ 9:00 am  | 2017-06-30 @ 12:00 pm | < 0.3        | 2017-07-03      |